

6 浄水場毎日検査

(1)水道用水毎日検査

高蔵寺浄水場	200	豊田浄水場	203
尾張東部浄水場	200	幸田浄水場	203
上野浄水場	201	豊橋浄水場	204
知多浄水場	201	豊橋南部浄水場	204
犬山浄水場	202	豊川浄水場	205
尾張西部浄水場	202		

(2)工業用水毎日検査

尾張東部浄水場(東郷)	206
上野浄水場	206
知多浄水場	206
尾張西部浄水場	207
安城浄水場	207
豊橋南部浄水場	207
蒲郡浄水場(工水)	208

(1)水道用水毎日検査

高蔵寺浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.9	27.1	28.6	31.9	34.3	30.3	26.9	19.2	14.3	10.4	10.6	14.2	34.3	
	最小	11.0	12.7	18.4	21.4	24.2	21.4	14.5	7.8	5.5	0.2	1.4	4.0	0.2	
	平均	17.4	22.0	24.4	27.9	30.2	26.3	21.3	14.1	9.3	5.9	6.1	9.8	17.9	
原水水温 (°C)	最大	15.1	18.5	21.0	22.9	24.9	23.9	19.7	15.6	10.8	7.3	6.5	9.5	24.9	
	最小	10.8	14.5	18.0	18.2	22.3	18.5	15.2	10.0	6.7	4.2	4.6	6.4	4.2	
	平均	12.4	16.0	19.3	21.1	24.0	21.5	17.7	13.0	8.6	5.6	5.2	7.9	14.4	
濁度 (度)	原水	最大	51.9	39.7	7.4	8.8	18.4	88.3	18.2	5.4	43.2	3.9	11.5	5.6	88.3
		最小	3.8	3.4	2.4	2.0	2.4	2.2	2.1	1.5	1.4	1.2	1.4	1.9	1.2
		平均	8.9	7.8	3.9	3.5	5.5	11.9	4.4	2.2	5.5	2.0	2.8	3.1	5.1
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	25.0	19.0	8.0	7.0	13.0	41.0	11.0	7.0	21.0	4.0	10.0	6.0	41.0
		最小	4.0	3.0	4.0	3.0	4.0	4.0	3.0	3.0	3.0	2.4	2.0	3.0	2.0
		平均	7.0	6.1	4.8	4.5	6.0	9.1	5.3	4.4	5.4	3.0	3.5	4.1	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.3	7.4
		最小	7.0	7.0	7.0	7.1	7.0	6.8	7.1	7.1	7.1	7.2	7.2	7.1	6.8
		平均	7.2	7.2	7.2	7.2	7.2	7.1	7.2	7.2	7.2	7.2	7.3	7.3	7.2
	浄水	最大	7.4	7.3	7.3	7.3	7.1	7.2	7.4	7.4	7.4	7.4	7.3	7.4	7.4
		最小	7.3	7.2	7.2	7.1	7.0	7.1	7.1	7.3	7.3	7.3	7.3	7.2	7.0
		平均	7.3	7.3	7.2	7.2	7.1	7.1	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	18.5	17.0	18.0	16.5	18.0	18.5	17.5	19.0	18.0	17.0	18.0	20.0	20.0
		最小	9.0	7.0	12.0	12.0	13.5	7.0	11.0	12.0	9.0	11.0	10.5	11.5	7.0
		平均	14.7	14.1	16.2	14.8	16.3	14.6	14.5	15.6	13.8	15.0	16.4	17.0	15.3
	浄水	最大	18.0	16.5	17.5	15.5	17.0	17.0	17.0	17.5	17.5	16.5	17.5	19.5	19.5
		最小	10.0	9.0	12.5	12.5	13.0	9.0	11.5	12.0	10.0	10.5	10.5	11.0	9.0
		平均	14.9	13.9	16.0	14.2	15.4	14.3	14.3	15.2	14.0	14.8	16.0	16.3	14.9
KMnO ₄ 消費量 (mg/l)	原水	最大	14.0	11.4	8.4	6.2	9.3	22.0	10.4	6.7	9.7	3.7	6.0	4.2	22.0
		最小	2.3	2.8	2.5	2.8	2.9	3.1	2.4	2.8	2.3	2.2	2.2	2.2	2.2
		平均	4.8	4.5	4.2	3.8	4.6	6.8	4.4	3.9	4.2	2.9	3.1	2.9	4.2
	浄水	最大	1.7	1.4	1.9	1.5	1.7	1.9	1.4	1.6	1.4	1.6	1.7	1.4	1.9
		最小	0.6	0.6	0.6	0.5	0.8	0.6	0.6	0.8	0.6	0.5	0.6	0.8	0.5
		平均	1.2	1.0	1.2	0.9	1.1	1.2	1.0	1.1	1.0	1.0	1.0	1.1	1.1
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.6
		最小	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4
		平均	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.4	0.4	0.4	0.4	0.5

尾張東部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.4	27.0	27.0	31.5	33.1	30.6	26.0	18.7	13.9	9.7	9.7	14.6	33.1	
	最小	11.5	15.5	17.6	21.5	23.8	18.4	13.7	7.2	5.3	-0.6	1.0	4.1	-0.6	
	平均	17.0	21.7	24.0	28.0	30.0	26.1	20.5	13.3	9.0	5.6	5.8	9.3	17.5	
原水水温 (°C)	最大	16.0	20.0	22.0	24.0	25.0	26.0	21.0	15.5	11.5	8.0	6.5	10.0	26.0	
	最小	11.0	16.0	19.5	21.0	24.0	19.5	15.5	10.5	7.5	5.0	5.0	6.5	5.0	
	平均	13.4	17.5	21.0	22.9	24.6	22.5	18.3	13.2	9.2	6.1	5.6	8.1	15.2	
濁度 (度)	原水	最大	21.8	11.2	6.3	6.6	10.9	89.0	11.9	3.8	32.6	5.8	10.5	5.4	89.0
		最小	4.1	3.1	2.3	1.9	1.7	1.9	1.7	1.5	1.4	1.3	1.2	1.7	1.2
		平均	6.5	6.2	3.9	3.6	4.2	12.4	3.4	2.1	5.2	2.0	2.5	3.0	4.6
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	8.4	5.4	7.3	6.8	12.4	66.5	9.3	6.9	16.6	4.5	7.2	4.9	66.5
		最小	3.0	3.0	2.8	3.5	2.6	3.4	2.9	1.5	1.3	2.0	1.7	2.4	1.3
		平均	4.3	4.4	4.4	4.5	4.8	9.0	4.7	3.8	4.8	2.5	3.1	3.5	4.5
	浄水	最大	0.8	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.6	7.5	7.5	7.6	7.7	7.6	7.6	7.6	7.5	7.5	7.4	7.5	7.7
		最小	7.3	7.2	7.2	7.1	7.1	7.1	7.1	7.3	7.1	7.2	7.2	7.1	7.1
		平均	7.4	7.4	7.4	7.3	7.4	7.3	7.4	7.4	7.3	7.3	7.3	7.3	7.4
	浄水	最大	7.2	7.2	7.3	7.2	7.2	7.2	7.3	7.3	7.2	7.2	7.2	7.2	7.3
		最小	7.1	7.1	7.0	7.0	7.0	7.0	7.1	7.1	7.1	7.0	7.0	7.1	7.0
		平均	7.1	7.1	7.1	7.1	7.1	7.1	7.2	7.2	7.1	7.1	7.1	7.1	7.1
アルカ度 (mg/l)	原水	最大	16.0	16.5	18.0	16.5	19.0	18.5	18.0	18.5	18.0	17.5	18.0	19.5	19.5
		最小	12.5	13.0	15.5	14.0	14.5	7.5	12.0	12.5	9.0	10.0	10.5	10.5	7.5
		平均	14.7	14.7	16.7	15.4	16.5	15.0	14.5	15.4	13.8	14.7	15.9	16.3	15.3
	浄水	最大	14.5	17.0	17.0	15.5	16.0	16.5	15.0	16.0	16.0	15.5	16.0	17.5	17.5
		最小	12.0	11.5	13.0	12.5	13.0	8.5	10.5	10.0	9.5	9.0	10.0	10.0	8.5
		平均	13.1	13.3	14.7	13.8	14.8	13.6	12.9	13.4	12.6	13.0	14.4	14.6	13.7
KMnO ₄ 消費量 (mg/l)	原水	最大	6.1	5.0	6.6	4.7	6.3	27.8	5.4	5.4	8.6	4.0	5.9	5.6	27.8
		最小	2.5	3.1	2.7	3.1	2.8	2.6	2.5	1.5	2.0	2.0	1.8	1.5	
		平均	3.8	4.0	3.9	4.0	4.1	5.9	3.7	3.0	3.8	2.6	3.3	3.0	3.8
	浄水	最大	1.2	1.3	1.6	1.6	1.4	1.4	1.4	1.2	1.4	1.1	1.5	1.5	1.6
		最小	0.6	0.6	0.5	0.6	0.6	0.5	0.5	0.3	0.3	0.5	0.8	0.5	0.3
		平均	0.9	0.9	1.0	1.0	0.9	0.9	0.9	0.8	0.9	0.8	1.1	0.9	0.9
残留塩素 (mg/l)	浄水	最大	0.7	0.7	0.8	0.8	0.9	0.8	0.8	0.7	0.7	0.7	0.7	0.6	0.9
		最小	0.5	0.6	0.6	0.7	0.8	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.5
		平均	0.6	0.7	0.7	0.8	0.8	0.8	0.7	0.6	0.6	0.6	0.6	0.6	0.7

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.5	26.5	27.0	31.5	33.5	31.0	26.0	18.5	14.5	10.5	9.0	14.0	33.5	
	最小	11.0	15.0	18.5	21.0	24.5	21.0	13.5	8.5	5.5	0.0	3.0	5.0	0.0	
	平均	16.8	21.7	23.9	28.1	29.9	26.2	20.6	13.5	8.8	5.3	5.6	9.2	17.5	
原水水温 (°C)	最大	15.5	20.0	22.0	24.5	26.5	26.0	22.0	16.5	11.5	8.5	6.5	10.0	26.5	
	最小	11.0	16.0	19.5	21.5	25.0	21.5	17.0	11.5	8.0	5.0	5.0	6.5	5.0	
	平均	13.2	17.7	21.0	23.1	25.9	23.9	19.9	14.0	9.5	6.4	5.6	8.3	15.7	
濁度 (度)	原水	最大	8.5	8.5	7.2	5.3	8.1	14.6	8.5	5.4	5.8	3.6	2.9	6.2	14.6
		最小	3.1	3.7	2.2	2.4	3.0	3.4	2.7	2.3	2.0	1.8	1.5	3.3	1.5
		平均	5.3	5.9	4.2	3.6	4.9	7.9	4.5	3.4	2.8	2.2	1.9	4.5	4.3
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	5.3	6.5	9.5	8.0	8.7	9.1	6.9	5.8	6.2	4.8	3.1	3.4	9.5
		最小	3.0	3.0	4.1	4.4	4.6	4.7	4.1	3.4	3.9	2.4	0.9	1.0	0.9
		平均	4.0	5.2	6.1	6.0	6.8	6.9	5.0	4.2	4.6	3.5	1.9	2.1	4.7
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.5	7.5	7.6	7.5	7.4	7.7	7.7	7.7	7.5	7.6	7.7	7.7
		最小	7.3	7.2	7.2	7.2	7.3	7.1	7.2	7.4	7.3	7.3	7.4	7.3	7.1
		平均	7.3	7.4	7.4	7.3	7.4	7.3	7.4	7.5	7.5	7.4	7.5	7.5	7.4
	浄水	最大	7.5	7.4	7.3	7.2	7.1	7.2	7.3	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.4	7.2	7.1	7.1	7.0	7.0	7.2	7.3	7.3	7.4	7.3	7.4	7.0
		平均	7.4	7.3	7.2	7.1	7.0	7.1	7.3	7.4	7.4	7.4	7.4	7.4	7.3
アルカ度 (mg/l)	原水	最大	15.0	15.5	17.0	15.5	17.0	17.0	15.0	17.0	17.0	15.0	16.0	17.0	17.0
		最小	13.0	12.0	14.0	14.0	14.0	12.0	12.5	14.0	13.0	13.0	15.0	14.0	12.0
		平均	14.1	13.7	15.9	14.5	15.7	15.2	13.7	15.7	15.5	14.0	15.7	15.5	14.9
	浄水	最大	15.5	15.0	16.5	15.0	15.0	16.0	14.5	17.0	16.5	15.0	16.0	16.5	17.0
		最小	13.0	12.0	13.0	12.5	13.0	11.5	12.0	13.5	13.5	12.5	15.0	14.0	11.5
		平均	14.3	13.7	14.9	13.7	14.0	14.2	13.4	15.6	15.4	13.9	15.6	15.0	14.5
KMnO ₄ 消費量 (mg/l)	原水	最大	4.7	4.7	4.8	5.1	5.7	7.0	4.9	6.5	4.7	4.5	3.2	3.8	7.0
		最小	2.3	2.8	2.5	3.2	3.0	3.6	3.0	3.0	3.2	2.1	2.1	2.8	2.1
		平均	3.3	3.9	3.3	3.9	4.0	4.6	3.8	3.9	3.9	3.0	2.5	3.3	3.6
	浄水	最大	1.1	1.2	1.3	1.3	1.3	1.3	1.1	1.1	1.4	1.0	1.0	1.1	1.4
		最小	0.6	0.6	0.6	0.6	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.6	0.5
		平均	0.8	0.9	0.8	0.9	0.8	0.9	0.8	0.8	0.9	0.8	0.8	0.9	0.8
残留塩素 (mg/l)	浄水	最大	0.4	0.5	0.6	0.6	0.6	0.7	0.6	0.6	0.6	0.5	0.4	0.5	0.7
		最小	0.4	0.4	0.5	0.5	0.5	0.6	0.6	0.5	0.5	0.4	0.4	0.4	0.4
		平均	0.4	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.5

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.0	27.0	29.0	33.0	34.0	32.0	27.0	23.0	14.0	13.0	15.0	15.0	34.0	
	最小	10.0	16.0	19.0	20.0	24.0	22.0	14.0	8.0	5.0	1.0	3.0	4.0	1.0	
	平均	17.4	22.2	23.3	28.5	31.0	27.0	21.5	14.1	9.6	5.7	6.5	9.4	18.0	
原水水温 (°C)	最大	19.0	24.0	26.0	28.0	30.5	29.5	22.5	17.5	12.5	9.0	9.0	12.5	30.5	
	最小	13.5	17.0	21.5	22.5	27.5	21.0	18.0	13.0	9.0	7.0	7.0	9.0	7.0	
	平均	15.9	20.1	23.1	25.9	29.0	25.2	20.4	15.2	10.9	7.9	8.0	10.9	17.7	
濁度 (度)	原水	最大	13.0	9.2	9.3	10.8	10.3	75.0	12.2	6.2	7.8	5.9	10.4	8.9	75.0
		最小	3.9	3.1	3.4	3.5	3.9	4.3	2.7	2.3	2.6	1.9	2.5	3.4	1.9
		平均	6.2	5.4	6.0	6.1	5.9	12.1	6.3	4.1	4.7	3.4	4.1	5.3	5.8
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	14.0	11.0	13.0	9.8	10.0	33.0	12.0	8.0	10.0	6.9	8.2	8.1	33.0
		最小	3.6	4.6	6.9	3.5	5.6	5.5	3.4	3.4	3.6	3.5	3.3	4.1	3.3
		平均	5.8	6.5	8.1	6.9	7.6	7.4	5.5	5.2	6.0	4.8	5.0	5.6	6.2
	浄水	最大	<0.5	<0.5	0.5	0.5	0.5	0.5	0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.8	7.8	7.7	8.7	8.3	7.5	7.5	7.6	7.5	7.5	7.5	7.7	8.7
		最小	7.0	7.1	6.9	6.9	6.9	6.9	7.1	7.2	7.2	7.3	7.2	7.2	6.9
		平均	7.3	7.2	7.0	7.3	7.3	7.1	7.3	7.4	7.4	7.4	7.4	7.4	7.3
	浄水	最大	7.3	7.4	7.3	7.4	7.4	7.3	7.4	7.3	7.3	7.3	7.4	7.4	7.4
		最小	7.2	7.2	7.2	7.2	7.2	7.2	7.1	7.2	7.3	7.2	7.2	7.2	7.1
		平均	7.3	7.3	7.0	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	34.5	31.0	36.5	34.0	34.5	33.5	33.5	35.0	36.0	36.0	34.0	36.5	
		最小	15.5	18.5	19.0	21.0	19.5	14.0	21.5	23.0	19.5	22.0	19.5	22.0	14.0
		平均	25.2	25.0	29.8	28.1	28.1	26.1	27.9	31.6	30.2	31.3	31.6	30.2	28.8
	浄水	最大	33.0	31.0	36.5	33.0	33.0	35.0	32.0	34.5	34.0	34.5	35.0	32.0	36.5
		最小	17.0	19.0	22.0	24.5	22.5	15.5	22.5	23.0	21.0	21.5	20.0	21.0	15.5
		平均	25.0	25.5	30.0	28.9	29.0	27.4	27.6	30.0	29.4	29.7	30.6	28.6	28.5
KMnO ₄ 消費量 (mg/l)	原水	最大	5.9	5.6	6.3	6.0	5.7	10.0	6.9	6.0	5.4	4.1	5.4	4.8	10.0
		最小	1.9	2.5	3.8	3.1	3.2	2.8	1.9	2.2	2.5	1.9	2.2	2.2	1.9
		平均	3.5	3.8	5.1	4.3	4.7	5.4	3.5	3.4	3.8	2.8	3.1	3.3	3.9
	浄水	最大	1.2	1.6	1.9	1.6	1.9	1.9	0.9	1.6	1.6	1.6	1.6	1.9	1.9
		最小	0.6	0.6	0.6	0.3	0.9	0.3	0.3	0.6	0.9	0.6	0.6	0.3	0.3
		平均	0.8	1.0	1.2	0.9	1.2	1.2	0.6	1.1	1.1	0.9	1.0	0.8	1.0
残留塩素 (mg/l)	浄水	最大	0.5	0.6	0.8	0.8	0.8	0.8	0.6	0.5	0.5	0.5	0.5	0.8	
		最小	0.5	0.5	0.5	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.4	0.4	
		平均	0.5	0.5	0.6	0.7	0.8	0.7	0.6	0.5	0.5	0.5	0.5	0.5	0.6

大山浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.3	28.3	27.0	31.0	33.0	30.1	25.5	18.4	12.3	10.2	9.9	12.8	33.0	
	最小	10.4	15.3	18.6	21.0	23.4	21.3	12.6	7.5	4.2	-0.3	0.6	3.3	-0.3	
	平均	16.7	21.5	23.9	27.4	29.7	25.9	20.2	13.4	8.4	5.1	5.5	8.9	17.2	
原水水温 (°C)	最大	14.3	18.1	21.8	23.1	25.2	24.1	19.2	14.2	10.2	6.3	5.9	8.9	25.2	
	最小	10.7	13.9	18.2	18.8	22.3	18.0	14.2	9.6	6.6	3.7	3.9	6.1	3.7	
	平均	12.2	16.0	19.7	21.5	24.1	21.4	17.2	12.2	8.2	5.0	4.8	7.3	14.1	
濁度 (度)	原水	最大	44.0	28.3	17.1	7.2	18.2	104.4	11.4	2.9	21.7	2.1	10.1	3.6	104.4
		最小	2.1	2.0	2.0	1.8	1.9	2.2	1.3	1.0	1.1	1.0	1.2	1.5	1.0
		平均	6.8	5.1	3.9	3.1	4.7	13.4	3.5	1.7	4.3	1.6	2.8	2.3	4.4
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	21.1	15.1	13.6	7.1	8.8	35.4	6.8	5.3	10.0	3.5	9.7	5.3	35.4
		最小	2.8	2.8	3.2	2.8	3.5	4.3	2.3	2.2	2.6	2.3	2.6	2.6	2.2
		平均	5.4	4.5	5.0	4.2	5.1	8.8	4.0	3.4	4.7	2.8	3.6	3.5	4.6
	浄水	最大	<0.5	<0.5	<0.5	<0.5	0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.3	7.3	7.2	7.3	7.2	7.3	7.4	7.3	7.5	7.4	7.4	7.5	
		最小	6.9	7.0	7.0	7.0	7.0	7.0	7.2	7.1	7.1	7.2	7.1	7.2	
		平均	7.1	7.2	7.1	7.2	7.1	7.2	7.3	7.2	7.3	7.4	7.3	7.3	7.2
	浄水	最大	7.4	7.4	7.4	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.3	7.3	7.4
		最小	7.4	7.3	7.2	7.1	7.1	7.1	7.3	7.3	7.3	7.3	7.3	7.2	7.1
		平均	7.4	7.4	7.3	7.2	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	17.5	16.5	18.5	17.5	18.5	17.5	17.0	18.0	17.5	18.0	19.0	20.0	20.0
		最小	9.0	8.5	11.5	13.5	12.0	8.5	11.0	13.0	9.5	12.5	10.5	12.5	8.5
		平均	14.5	14.1	16.8	15.1	16.3	14.4	14.3	15.9	14.3	15.7	16.2	17.1	15.4
	浄水	最大	18.0	16.5	19.5	17.0	18.5	18.0	18.0	18.5	18.0	17.5	19.5	20.0	20.0
		最小	9.0	9.0	11.5	13.5	12.5	10.0	12.0	13.0	10.5	12.5	10.5	12.5	9.0
		平均	14.8	14.2	17.0	15.0	16.4	14.6	14.7	16.2	14.6	15.7	16.6	16.9	15.6
KMnO ₄ 消費量 (mg/l)	原水	最大	10.4	9.5	9.1	5.7	9.8	31.9	5.9	5.3	8.1	3.8	5.4	4.1	31.9
		最小	2.8	3.1	3.2	2.8	2.5	3.8	2.8	3.1	2.5	2.2	2.8	2.8	2.2
		平均	4.2	4.2	4.6	4.0	4.8	7.3	4.0	3.9	4.1	3.0	3.5	3.3	4.2
	浄水	最大	1.6	1.6	1.9	1.6	1.9	1.9	1.9	1.6	1.6	1.6	1.6	1.9	1.9
		最小	0.6	0.6	0.9	0.9	0.9	0.9	0.6	0.6	0.6	0.6	0.9	0.9	0.6
		平均	1.0	1.2	1.3	1.1	1.4	1.3	1.0	1.2	1.0	1.1	1.2	1.2	1.2
残留塩素 (mg/l)	浄水	最大	0.5	0.5	0.7	0.7	0.7	0.7	0.6	0.5	0.6	0.5	0.5	0.7	
		最小	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.4	0.4	0.4	
		平均	0.5	0.5	0.6	0.6	0.7	0.7	0.5	0.5	0.5	0.5	0.4	0.4	

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.4	28.2	28.9	32.0	33.7	30.0	25.2	20.0	14.1	11.8	9.5	13.7	33.7	
	最小	10.8	15.7	18.2	21.2	24.3	21.0	12.5	8.5	4.0	-0.1	1.3	4.8	-0.1	
	平均	17.0	21.5	23.7	27.2	29.6	26.2	20.7	14.2	9.0	5.3	5.5	9.5	17.5	
原水水温 (°C)	最大	16.5	20.5	24.6	25.5	28.4	27.8	20.5	15.7	11.7	8.0	7.6	11.3	28.4	
	最小	11.9	15.3	19.4	20.3	24.0	19.0	15.4	10.4	7.7	4.6	5.1	7.5	4.6	
	平均	13.7	17.8	22.1	23.5	26.5	23.3	18.5	13.6	9.4	6.3	6.2	9.1	15.8	
濁度 (度)	原水	最大	28.9	27.0	10.9	11.2	23.0	84.8	15.0	3.9	18.8	4.6	6.1	4.7	84.8
		最小	2.4	2.3	2.6	4.0	3.1	2.7	1.8	1.3	1.5	1.1	1.1	1.4	1.1
		平均	6.3	5.7	4.7	6.1	7.9	13.8	5.1	2.4	4.6	1.9	2.3	2.5	5.3
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	16.0	16.8	9.5	7.7	15.3	40.3	10.0	5.4	11.6	5.7	7.0	5.8	40.3
		最小	3.5	3.8	4.0	4.1	3.5	4.3	2.6	2.4	2.2	2.1	2.4	2.2	2.1
		平均	6.0	5.8	5.5	5.6	6.3	8.7	4.9	4.0	5.0	3.1	3.6	3.4	5.2
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.3	7.5	7.6	7.3	7.3	7.4	7.5	7.7	7.4	7.6	7.7	7.6	7.7
		最小	6.8	6.9	7.0	7.1	6.9	6.8	7.0	7.3	7.2	7.3	7.2	7.3	6.8
		平均	7.1	7.2	7.2	7.2	7.2	7.2	7.3	7.5	7.3	7.4	7.6	7.5	7.3
	浄水	最大	7.3	7.4	7.5	7.5	7.4	7.3	7.3	7.4	7.4	7.3	7.4	7.3	7.5
		最小	7.3	7.3	7.2	7.3	7.2	7.2	7.2	7.2	7.3	7.3	7.2	7.2	7.2
		平均	7.3	7.3	7.3	7.4	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	19.5	18.0	22.0	18.5	21.0	20.5	17.5	20.0	19.0	18.0	19.5	21.0	22.0
		最小	11.0	10.0	14.0	14.0	13.0	9.5	13.0	14.5	10.0	12.0	12.5	13.0	9.5
		平均	15.7	15.1	18.5	16.6	17.5	16.1	15.6	17.2	15.4	16.3	17.6	17.6	16.6
	浄水	最大	18.0	17.5	22.0	19.5	21.0	20.0	17.0	18.5	18.0	18.0	19.0	19.0	22.0
		最小	12.0	11.5	14.0	15.0	14.5	11.0	13.0	13.5	11.0	12.5	13.0	11.5	11.0
		平均	15.2	15.2	18.6	16.7	17.8	16.1	15.3	16.3	15.2	15.7	16.8	16.4	16.3
KMnO ₄ 消費量 (mg/l)	原水	最大	9.0	9.2	8.5	5.7	9.7	25.8	6.7	5.7	7.0	5.4	5.0	5.2	25.8
		最小	3.0	2.5	3.0	3.0	3.0	3.5	1.6	2.9	2.5	1.9	2.7	2.2	1.6
		平均	4.7	3.7	4.4	4.2	4.8	6.6	4.0	4.1	4.2	3.3	3.5	3.1	4.2
	浄水	最大	2.7	1.9	2.2	1.9	2.2	2.2	1.6	1.9	1.7	2.1	1.8	1.7	2.7
		最小	1.1	0.5	0.9	0.6	0.6	0.5	0.3	0.6	0.5	0.5	0.8	0.3	0.3
		平均	1.7	1.1	1.5	1.1	1.3	1.5	1.0	1.5	1.1	1.4	1.2	1.0	1.3
残留塩素 (mg/l)	浄水	最大	0.5	0.7	0.8	0.7	0.8	0.8	0.6	0.6	0.6	0.5	0.5	0.8	
		最小	0.4	0.5	0.7	0.6	0.7	0.5	0.5	0.4	0.4	0.4	0.4	0.4	
		平均	0.5	0.6	0.7	0.7	0.7	0.7	0.5	0.5	0.5	0.4	0.4	0.4	

豊田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.4	26.9	27.5	31.6	32.6	31.5	26.0	18.7	13.5	10.0	11.4	14.7	32.6	
	最小	9.5	15.3	17.8	20.8	23.9	21.0	14.2	7.8	4.0	-1.0	0.3	4.3	-1.0	
	平均	17.0	21.8	24.1	28.0	30.3	26.5	20.8	13.5	8.6	5.2	5.8	9.4	17.6	
原水水温 (°C)	最大	15.0	17.7	20.0	22.5	23.8	23.4	20.0	15.2	11.2	7.0	6.2	8.0	23.8	
	最小	8.4	14.0	17.2	19.5	21.9	17.5	14.7	9.5	6.0	3.5	3.5	4.5	3.5	
	平均	11.6	15.7	18.7	21.4	22.8	20.8	17.6	12.6	8.3	5.3	4.5	6.1	13.8	
濁度 (度)	原水	最大	12.8	45.5	8.6	40.4	72.9	334.7	21.9	7.3	93.6	6.8	7.8	4.8	334.7
		最小	1.2	2.8	1.4	2.6	2.7	2.5	2.0	1.4	2.0	1.6	1.7	1.6	1.2
		平均	3.1	6.0	2.8	5.4	10.0	17.6	4.2	2.3	6.8	2.5	2.5	2.5	5.5
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	9.9	33.6	10.1	38.9	81.7	182.7	14.0	8.1	85.8	6.4	8.4	4.6	182.7
		最小	2.6	3.4	3.6	4.3	3.2	6.4	4.3	3.5	3.5	2.7	2.5	2.4	2.4
		平均	4.1	5.8	5.0	7.5	11.9	14.7	6.0	4.4	8.2	3.5	3.5	3.3	6.5
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.7	7.5	7.3	7.4	7.4	7.3	7.4	7.4	7.4	7.6	7.5	7.5	7.7
		最小	7.3	7.2	7.1	7.1	7.2	6.9	7.2	7.3	7.2	7.3	7.3	7.3	6.9
		平均	7.4	7.3	7.3	7.3	7.2	7.2	7.3	7.4	7.3	7.4	7.4	7.4	7.3
	浄水	最大	7.5	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.5	7.4	7.4	7.4	7.5
		最小	7.3	7.3	7.3	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.2
		平均	7.4	7.3	7.3	7.4	7.4	7.4	7.4	7.3	7.4	7.3	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	18.0	17.5	20.5	20.0	20.0	19.5	20.5	21.0	20.5	19.0	18.5	18.0	21.0
		最小	14.0	14.0	16.5	17.0	15.0	13.0	16.0	19.0	12.5	16.0	16.5	16.0	12.5
		平均	15.5	15.6	18.3	18.0	18.0	17.1	17.9	20.1	17.8	17.6	17.3	16.9	17.5
	浄水	最大	16.0	17.0	19.0	19.0	19.5	19.0	19.0	20.0	20.0	18.0	17.5	17.0	20.0
		最小	13.0	13.5	16.0	16.0	15.5	13.0	15.5	18.0	15.0	15.0	15.0	15.0	13.0
		平均	14.6	14.7	17.3	17.7	17.7	17.0	17.0	18.9	17.4	16.9	16.4	15.9	16.8
KMnO ₄ 消費量 (mg/l)	原水	最大	10.6	30.0	8.8	25.2	24.2	165.7	16.8	8.7	32.9	6.0	6.7	5.4	165.7
		最小	3.0	3.6	1.4	4.4	5.0	4.3	3.4	2.5	1.9	2.1	1.4	1.6	1.4
		平均	5.0	6.4	4.1	7.0	8.6	12.5	5.5	3.8	4.6	3.3	2.6	2.8	5.5
	浄水	最大	1.7	2.4	1.6	2.1	2.7	2.2	1.6	1.2	1.1	2.2	1.3	1.7	2.7
		最小	0.6	0.5	0.3	0.8	0.8	0.1	0.5	0.3	0.3	0.3	0.1	0.1	0.1
		平均	1.2	1.6	0.7	1.4	1.3	1.0	1.0	0.7	0.7	1.2	0.7	0.6	1.0
残留塩素 (mg/l)	最大	0.6	0.6	0.6	0.8	0.9	0.8	0.8	0.7	0.6	0.6	0.7	0.6	0.9	
	最小	0.5	0.5	0.5	0.5	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	
	平均	0.5	0.5	0.5	0.7	0.8	0.7	0.7	0.6	0.6	0.6	0.6	0.6	0.6	

幸田浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.9	26.6	27.7	31.9	32.7	32.6	27.5	19.4	16.1	11.7	11.9	14.8	32.7	
	最小	11.9	15.5	18.2	20.8	25.4	21.6	15.1	7.6	6.1	0.9	3.1	6.1	0.9	
	平均	17.4	21.9	24.1	28.2	30.4	27.2	21.7	14.7	10.0	6.5	7.2	10.3	18.3	
原水水温 (°C)	最大	18.5	21.5	23.5	27.0	28.0	27.0	22.5	16.0	11.5	7.5	8.0	10.5	28.0	
	最小	12.0	16.0	19.5	22.5	26.0	21.5	17.0	11.5	7.0	4.0	5.0	6.5	4.0	
	平均	14.7	18.7	21.7	25.4	27.3	24.3	19.7	13.7	9.3	6.0	6.1	8.8	16.3	
濁度 (度)	原水	最大	24.0	21.0	25.0	26.0	9.4	41.0	11.0	3.8	36.0	6.5	5.5	5.1	41.0
		最小	3.5	3.3	2.5	2.0	2.0	2.6	1.5	1.1	0.8	0.8	0.7	0.7	0.7
		平均	9.0	8.3	7.2	6.7	4.4	9.6	3.3	1.8	3.9	1.5	1.3	1.6	4.9
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	30.0	37.0	38.0	42.0	17.0	59.0	14.0	11.0	39.0	10.0	11.0	10.0	59.0
		最小	5.9	7.0	6.9	6.1	6.4	7.0	5.2	4.5	3.7	3.1	3.1	3.4	3.1
		平均	11.2	11.9	11.6	11.4	9.2	14.3	7.8	5.9	7.1	4.3	4.3	4.9	8.7
	浄水	最大	0.6	<0.5	0.7	0.5	<0.5	0.6	0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.4	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5	7.5
		最小	7.3	7.3	7.3	7.3	7.4	7.2	7.4	7.4	7.3	7.3	7.3	7.4	7.2
		平均	7.4	7.4	7.4	7.4	7.5	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.4
	浄水	最大	7.4	7.5	7.5	7.4	7.4	7.5	7.5	7.5	7.4	7.4	7.5	7.5	7.5
		最小	7.4	7.3	7.3	7.4	7.3	7.3	7.4	7.4	7.3	7.4	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	20.5	20.0	21.0	21.5	22.0	21.5	20.0	21.0	20.5	19.0	21.0	21.0	22.0
		最小	15.0	11.5	14.5	15.5	17.0	11.0	16.0	18.0	13.5	17.0	15.0	18.0	11.0
		平均	18.5	17.1	19.3	20.3	19.5	18.0	18.1	20.0	18.5	18.3	18.8	19.5	18.8
	浄水	最大	18.5	19.0	19.5	20.5	20.0	20.0	18.5	20.0	19.5	18.5	19.0	19.5	20.5
		最小	16.0	14.5	17.5	17.0	16.0	10.5	14.5	17.0	12.0	16.5	15.0	16.5	10.5
		平均	17.5	16.5	18.5	19.0	18.1	16.7	16.7	18.8	17.5	17.3	18.0	18.4	17.8
KMnO ₄ 消費量 (mg/l)	原水	最大	13.6	20.4	22.5	23.8	13.8	34.8	11.1	7.5	18.2	5.5	9.0	7.8	34.8
		最小	4.1	6.1	5.5	4.7	5.0	4.7	3.4	3.1	3.1	2.5	2.3	2.4	2.3
		平均	8.1	8.9	8.8	8.6	7.0	10.2	5.9	4.7	5.2	3.4	3.4	3.8	6.5
	浄水	最大	2.1	1.9	2.2	2.2	1.6	2.6	1.9	1.9	2.2	1.7	1.9	1.9	2.6
		最小	0.8	0.8	0.6	0.8	0.8	0.8	0.8	0.9	0.9	0.5	0.3	0.8	0.3
		平均	1.4	1.2	1.4	1.5	1.3	1.5	1.3	1.4	1.4	1.1	1.0	1.1	1.3
残留塩素 (mg/l)	最大	0.7	0.8	0.9	1.0	1.0	0.9	0.8	0.7	0.7	0.6	0.3	0.6	1.0	
	最小	0.5	0.6	0.7	0.7	0.8	0.7	0.7	0.6	0.5	0.5	0.5	0.5	0.5	
	平均	0.6	0.6	0.8	0.9	0.9	0.8	0.7	0.6	0.6	0.5	0.5	0.5	0.7	

豊橋浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	27.0	28.0	31.0	32.0	30.0	27.0	19.0	16.0	10.0	15.0	15.0	32.0	
	最小	15.0	18.0	18.0	22.0	25.0	24.0	15.0	9.5	6.0	2.0	3.0	6.0	2.0	
	平均	18.4	22.9	24.6	28.7	30.3	27.1	21.8	15.1	10.4	6.7	7.3	10.5	18.7	
原水水温 (°C)	最大	18.0	21.5	24.0	27.0	28.5	26.5	22.5	16.5	11.5	7.0	8.0	11.5	28.5	
	最小	13.0	15.5	20.0	22.5	24.5	20.5	16.5	10.5	7.0	4.0	4.5	7.5	4.0	
	平均	14.9	18.3	21.6	25.4	26.9	23.6	19.6	13.7	9.0	5.6	6.0	9.2	16.2	
濁度 (度)	原水	最大	15.0	8.0	7.5	27.0	12.0	36.0	7.8	1.9	6.9	2.6	8.0	2.3	36.0
		最小	1.9	1.9	1.2	2.1	1.8	2.0	1.5	0.7	0.6	0.7	0.6	1.1	0.6
		平均	4.4	3.1	2.6	3.7	3.4	5.9	2.7	1.2	1.7	1.2	1.4	1.5	2.7
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	11.0	10.0	14.1	22.0	15.0	29.0	15.0	7.1	13.0	3.9	15.0	5.9	29.0
		最小	3.1	3.4	3.5	4.3	5.2	3.7	3.3	2.5	2.0	1.6	1.7	2.5	1.6
		平均	5.8	4.8	5.8	6.5	7.8	9.5	5.7	3.9	4.3	2.3	3.3	3.8	5.3
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.4	7.4	7.5	7.4	7.4	7.5	7.6	7.6	7.6	7.7	7.6	7.7
		最小	7.1	7.1	7.3	7.3	7.1	7.1	7.3	7.4	7.2	7.4	7.1	7.3	7.1
		平均	7.4	7.3	7.3	7.4	7.3	7.3	7.4	7.5	7.5	7.5	7.5	7.5	7.4
	浄水	最大	7.5	7.4	7.4	7.5	7.4	7.4	7.5	7.4	7.4	7.4	7.4	7.4	7.5
		最小	7.4	7.4	7.4	7.3	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	23.0	23.0	26.5	28.0	26.0	26.0	24.0	25.0	25.0	24.5	25.5	25.0	28.0
		最小	12.0	12.0	19.0	20.0	16.5	11.0	16.5	21.5	13.5	19.5	12.5	20.0	11.0
		平均	19.1	18.7	23.4	24.9	22.2	20.2	20.6	23.6	21.5	22.3	22.5	23.0	21.8
	浄水	最大	21.0	22.0	23.0	23.0	23.0	23.0	21.0	22.5	23.0	22.0	22.5	23.0	23.0
		最小	13.5	12.0	18.5	19.0	13.0	12.0	14.5	18.0	13.0	17.5	13.0	18.0	12.0
		平均	17.6	17.5	21.1	21.8	19.3	18.3	18.5	20.5	19.5	20.8	20.3	20.9	19.7
KMnO ₄ 消費量 (mg/l)	原水	最大	11.0	8.2	11.4	13.0	16.0	15.0	11.0	6.3	8.8	3.8	11.0	6.3	16.0
		最小	2.5	3.3	3.1	3.3	3.7	4.1	2.8	2.2	2.5	1.2	2.2	2.5	1.2
		平均	5.4	4.2	5.3	5.3	6.2	7.3	5.1	3.7	4.1	2.5	3.2	3.8	4.7
	浄水	最大	2.1	1.2	1.5	1.8	1.6	1.9	1.6	1.2	1.6	1.2	1.3	1.9	2.1
		最小	0.6	0.6	0.6	0.6	0.6	0.9	0.6	0.6	0.6	0.6	0.6	0.6	0.6
		平均	1.2	0.8	1.2	1.1	1.1	1.2	1.0	1.0	1.0	0.7	0.9	1.0	1.0
残留塩素 (mg/l)	最大	0.5	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.5	0.6	
	最小	0.4	0.5	0.5	0.5	0.6	0.5	0.5	0.4	0.4	0.4	0.4	0.4	0.4	
	平均	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.4	0.5	

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.2	26.3	27.3	31.0	32.6	31.2	26.4	19.7	16.4	11.4	12.5	14.8	32.6	
	最小	11.7	15.4	19.3	19.9	25.4	22.7	15.1	8.7	6.1	0.6	3.8	5.7	0.6	
	平均	17.4	21.7	24.0	27.7	30.0	26.5	21.4	14.4	10.1	6.3	6.8	9.7	18.0	
原水水温 (°C)	最大	15.1	18.2	21.3	23.7	27.0	25.5	23.5	18.5	13.8	10.1	7.5	10.0	27.0	
	最小	10.8	15.2	17.5	21.3	23.7	22.6	18.6	13.5	10.3	6.6	6.3	7.5	6.3	
	平均	12.8	16.8	19.2	22.6	24.4	24.0	21.3	16.0	11.7	8.0	6.9	8.6	16.0	
濁度 (度)	原水	最大	5.2	6.0	5.3	4.0	5.3	28.4	2.0	2.0	2.3	2.1	3.3	2.5	28.4
		最小	1.9	2.2	1.0	1.3	1.5	1.1	0.8	1.1	1.2	1.2	1.6	1.3	0.8
		平均	2.7	3.0	2.0	2.1	2.3	3.8	1.2	1.6	1.8	1.6	2.1	1.7	2.2
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	6.7	9.8	7.7	9.0	9.1	27.2	6.9	9.5	6.0	4.3	8.3	4.5	27.2
		最小	3.3	3.1	3.2	4.3	3.1	3.9	3.6	4.0	3.5	2.4	3.0	3.3	2.4
		平均	4.1	4.4	5.2	5.7	4.6	6.6	4.8	5.1	4.6	3.4	3.7	3.7	4.7
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.6	7.4	7.5	8.1	8.8	7.6	7.8	7.8	7.7	7.6	7.7	8.8
		最小	7.1	7.2	7.2	7.0	7.1	7.1	7.1	7.4	7.5	7.4	7.5	7.5	7.0
		平均	7.3	7.4	7.2	7.3	7.5	7.5	7.3	7.6	7.6	7.5	7.5	7.6	7.4
	浄水	最大	7.5	7.5	7.5	7.5	7.5	7.5	7.4	7.5	7.4	7.4	7.5	7.5	7.5
		最小	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.4	7.3	7.4	7.4	7.4	7.3
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4
アルカ度 (mg/l)	原水	最大	19.0	19.0	19.0	27.0	28.5	27.0	21.0	22.5	22.0	21.5	24.5	28.5	
		最小	14.5	13.5	14.5	16.0	17.5	15.0	17.5	17.0	17.5	17.0	16.0	17.5	13.5
		平均	16.9	16.4	16.4	22.1	19.7	19.3	19.6	20.4	19.7	19.8	19.4	20.3	19.2
	浄水	最大	17.5	17.5	17.5	24.5	26.5	24.5	20.0	19.5	20.5	20.5	19.5	22.0	26.5
		最小	13.5	13.5	14.0	15.5	16.0	15.5	16.0	16.0	16.0	17.0	15.0	15.5	13.5
		平均	15.7	15.5	15.9	20.7	17.7	17.9	18.3	18.2	18.1	18.3	17.5	18.4	17.7
KMnO ₄ 消費量 (mg/l)	原水	最大	8.9	9.7	9.0	8.7	9.7	15.6	7.5	11.0	7.3	6.4	9.6	5.3	15.6
		最小	4.3	4.0	4.0	4.5	4.6	3.9	3.7	4.0	4.0	3.4	3.4	4.1	3.4
		平均	5.4	5.4	5.6	5.7	5.9	5.9	4.8	5.4	5.4	4.2	4.8	4.6	5.3
	浄水	最大	1.5	1.6	1.9	1.6	1.9	1.5	1.5	1.6	1.3	1.2	1.3	1.3	1.9
		最小	0.3	0.3	0.6	0.3	0.3	0.3	0.6	0.6	0.3	0.3	0.3	0.3	0.3
		平均	0.9	0.9	1.1	1.3	1.0	1.0	1.0	1.0	0.9	0.8	0.9	0.9	1.0
残留塩素 (mg/l)	最大	0.6	0.6	0.7	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.7	
	最小	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.4	0.4	0.5	0.4	
	平均	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.6	

豊川浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.9	29.6	29.9	33.8	34.2	33.1	26.7	19.3	14.3	10.2	14.4	16.9	34.2	
	最小	12.7	15.9	19.3	20.2	25.8	22.4	14.4	8.1	6.1	0.3	3.9	6.3	0.3	
	平均	18.5	23.3	24.8	29.3	31.5	27.1	21.5	14.2	9.9	6.2	7.2	10.8	18.7	
原水水温 (°C)	最大	18.0	21.6	22.0	26.0	27.0	24.0	23.4	18.9	14.0	10.0	9.5	12.0	27.0	
	最小	10.5	17.8	19.5	22.5	21.7	22.0	19.0	13.1	10.0	6.8	7.0	9.0	6.8	
	平均	15.6	19.6	20.6	24.7	24.8	23.2	21.6	16.0	11.4	8.1	7.9	10.5	17.0	
濁度 (度)	原水	最大	2.4	1.9	2.4	5.6	4.2	4.4	2.1	2.1	2.3	2.1	2.0	2.8	5.6
		最小	0.6	0.7	0.8	0.9	1.0	1.1	0.8	1.0	1.1	0.8	1.1	1.0	0.6
		平均	1.3	1.4	1.5	1.9	2.0	1.9	1.4	1.5	1.7	1.4	1.4	1.8	1.6
	浄水	最大	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		最小	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
		平均	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1
色度 (度)	原水	最大	6.2	6.4	10.0	8.1	7.7	10.6	8.0	5.8	6.0	5.9	6.1	5.7	10.6
		最小	3.8	4.5	4.6	3.0	4.4	6.2	5.2	4.3	4.8	3.4	3.7	3.0	3.0
		平均	4.9	5.5	6.8	5.2	6.6	8.0	6.4	5.1	5.4	4.3	4.5	4.3	5.6
	浄水	最大	<0.5	<0.5	<0.5	<0.5	<0.5	0.6	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	0.6
		最小	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
		平均	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5
pH値	原水	最大	7.5	7.4	7.2	8.0	7.9	7.5	7.3	7.4	7.5	7.5	7.5	7.5	8.0
		最小	7.2	7.0	7.1	7.2	7.1	7.0	7.0	7.2	7.3	7.3	7.4	7.4	7.0
		平均	7.4	7.2	7.2	7.6	7.4	7.2	7.2	7.3	7.4	7.4	7.5	7.4	7.3
	浄水	最大	7.5	7.4	7.5	7.5	7.5	7.4	7.5	7.5	7.4	7.5	7.4	7.4	7.5
		最小	7.4	7.3	7.3	7.2	7.3	7.3	7.3	7.2	7.3	7.3	7.3	7.3	7.2
		平均	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.4	7.3	7.3	7.4
アルカ度 (mg/l)	原水	最大	17.0	16.0	17.5	35.0	33.0	29.0	20.0	21.5	22.5	21.5	20.5	23.0	35.0
		最小	14.5	13.0	13.5	14.5	15.0	14.0	16.0	17.5	17.0	16.0	16.5	16.0	13.0
		平均	15.5	14.8	14.8	27.5	19.0	18.0	18.0	19.5	19.9	18.4	19.0	18.8	18.6
	浄水	最大	16.5	16.0	17.0	33.0	31.5	25.5	20.0	21.0	21.0	20.0	20.0	22.5	33.0
		最小	13.0	12.0	14.0	15.0	15.5	16.0	15.0	17.0	17.0	15.5	16.0	15.5	12.0
		平均	15.4	15.2	15.3	25.0	18.8	18.3	18.0	19.4	19.4	18.0	18.4	18.5	18.3
KMnO ₄ 消費量 (mg/l)	原水	最大	5.8	5.9	8.7	7.7	7.0	7.9	7.2	5.2	6.6	5.5	6.4	5.5	8.7
		最小	3.2	3.2	3.8	3.3	3.6	4.6	3.9	3.2	3.6	3.3	3.6	3.6	3.2
		平均	4.9	4.6	5.9	4.6	5.7	6.0	4.9	4.0	4.8	4.0	4.5	4.2	4.8
	浄水	最大	1.8	1.5	1.7	1.8	1.8	2.4	1.5	1.5	2.1	1.5	1.8	1.5	2.4
		最小	0.2	0.2	0.4	0.8	0.9	0.9	0.6	0.2	0.6	0.6	0.6	0.6	0.2
		平均	1.1	0.9	1.1	1.2	1.4	1.3	1.2	0.8	1.0	1.1	1.3	1.1	1.1
残留塩素 (mg/l)	浄水	最大	0.6	0.7	0.6	0.7	0.7	0.7	0.6	0.6	0.5	0.5	0.5	0.5	0.7
		最小	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.5	0.5	0.4	0.4	0.5	0.4
		平均	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.5	0.5	0.5	0.5	0.5	0.6

(2)工業用水毎日検査

尾張東部浄水場(東郷)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	20.0	25.0	26.0	31.0	32.0	30.0	25.0	15.0	11.0	6.0	8.0	12.0	32.0	
	最小	8.0	15.0	17.0	19.0	22.0	19.0	11.0	5.0	2.0	-1.0	-1.0	3.0	-1.0	
	平均	15.3	20.5	22.7	27.4	29.1	24.5	18.5	10.6	5.8	2.4	3.1	7.1	15.6	
原水水温 (°C)	最大	15.0	19.0	22.0	24.0	26.0	25.5	21.0	17.0	11.5	8.0	7.0	9.0	26.0	
	最小	10.5	15.0	19.0	21.0	24.0	21.5	17.5	11.5	8.0	5.0	5.0	6.5	5.0	
	平均	12.7	17.0	20.5	22.7	25.4	23.6	19.5	13.9	9.2	6.2	5.3	7.8	15.3	
濁度 (度)	原水	最大	8.0	6.0	6.0	5.0	8.0	24.0	8.0	9.0	5.0	4.0	2.0	3.0	24.0
		最小	3.0	2.0	1.0	2.0	3.0	4.0	3.0	2.0	1.0	1.0	1.0	1.0	1.0
		平均	3.0	3.0	3.0	3.0	4.0	8.0	5.0	3.0	2.0	1.0	1.0	2.0	3.2
	配水	最大	8.0	4.0	2.0	2.0	6.0	8.0	5.0	3.0	4.0	3.0	2.0	3.0	8.0
		最小	2.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	2.0	2.0	1.0	1.0	2.0	3.0	2.0	1.0	1.0	1.0	1.0	1.0	1.5
pH値	原水	最大	7.4	7.4	7.3	7.5	7.4	7.3	7.6	8.2	7.7	7.5	7.6	7.9	8.2
		最小	7.2	7.0	7.0	7.0	7.0	6.9	7.0	7.1	7.3	7.3	7.4	7.4	6.9
		平均	7.3	7.2	7.2	7.2	7.2	7.1	7.4	7.7	7.5	7.4	7.5	7.6	7.4
	配水	最大	7.4	7.3	7.3	7.4	7.3	7.3	7.4	7.4	7.4	7.4	7.4	7.4	7.4
		最小	7.2	7.1	7.1	7.1	7.1	6.7	6.8	7.3	7.2	7.1	7.2	7.3	6.7
		平均	7.3	7.2	7.2	7.2	7.2	7.1	7.3	7.3	7.3	7.3	7.3	7.3	7.3
アルカ度 (mg/l)	原水	最大	15.5	17.0	19.5	16.0	17.5	18.0	17.0	18.0	17.0	16.0	17.0	18.0	19.5
		最小	12.0	13.0	15.0	14.5	15.0	12.0	13.0	14.0	14.5	13.0	15.5	14.5	12.0
		平均	14.7	14.9	16.6	15.4	16.5	15.7	14.5	16.3	16.0	14.7	16.5	16.0	15.6
	配水	最大	15.5	16.0	17.5	16.0	17.5	18.0	15.0	17.0	16.5	15.5	16.5	16.5	18.0
		最小	13.0	13.0	15.0	14.0	14.5	10.5	12.0	14.0	13.5	11.5	15.0	13.5	10.5
		平均	14.3	14.6	16.4	15.1	16.2	15.0	13.7	15.0	15.1	14.0	15.8	15.0	15.0

上野浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	21.5	26.5	27.0	31.5	33.5	31.0	26.0	18.5	14.5	10.5	9.0	14.0	33.5	
	最小	11.0	15.0	18.5	21.0	24.5	21.0	13.5	8.5	5.5	0.0	3.0	5.0	0.0	
	平均	16.8	21.7	23.9	28.1	29.9	26.2	20.6	13.5	8.8	5.3	5.6	9.2	17.5	
原水水温 (°C)	最大	15.5	20.0	22.0	24.5	26.5	26.0	22.0	16.5	11.5	8.5	6.5	10.0	26.5	
	最小	11.0	16.0	19.5	21.5	25.0	21.5	17.0	11.5	8.0	5.0	5.0	6.5	5.0	
	平均	13.2	17.7	21.0	23.1	25.9	23.9	19.9	14.0	9.5	6.4	5.6	8.3	15.7	
濁度 (度)	原水	最大	8.5	8.5	7.2	5.3	8.1	14.6	8.5	5.4	5.8	3.6	2.9	6.2	14.6
		最小	3.1	3.7	2.2	2.4	3.0	3.4	2.7	2.3	2.0	1.8	1.5	3.3	1.5
		平均	5.3	5.9	4.2	3.6	4.9	7.9	4.5	3.4	2.8	2.2	1.9	4.5	4.3
	配水	最大	5.4	3.9	2.6	2.5	4.0	5.0	5.0	3.0	3.9	2.4	1.3	2.0	5.4
		最小	1.9	1.4	1.1	1.1	1.4	1.2	1.6	1.3	1.2	1.0	0.8	1.0	0.8
		平均	3.0	2.3	1.5	1.7	2.2	2.7	2.9	1.9	1.8	1.4	1.0	1.5	2.0
pH値	原水	最大	7.5	7.5	7.5	7.6	7.5	7.4	7.7	7.7	7.7	7.5	7.6	7.7	7.7
		最小	7.3	7.2	7.2	7.2	7.3	7.1	7.2	7.4	7.3	7.3	7.4	7.3	7.1
		平均	7.3	7.4	7.4	7.3	7.4	7.3	7.4	7.5	7.5	7.4	7.5	7.5	7.4
	配水	最大	7.3	7.3	7.2	7.2	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3	7.3
		最小	7.1	7.1	7.1	7.1	7.1	6.8	7.1	7.2	7.2	7.1	7.2	7.2	6.8
		平均	7.2	7.2	7.2	7.1	7.2	7.1	7.2	7.2	7.2	7.2	7.2	7.2	7.2
アルカ度 (mg/l)	原水	最大	15.0	15.5	17.0	15.5	17.0	17.0	15.0	17.0	17.0	15.0	16.0	17.0	17.0
		最小	13.0	12.0	14.0	14.0	14.0	12.0	12.5	14.0	13.0	13.0	15.0	14.0	12.0
		平均	14.1	13.7	15.9	14.5	15.7	15.2	13.7	15.7	15.5	14.0	15.7	15.5	14.9
	配水	最大	14.5	14.5	16.0	14.5	16.0	16.0	14.0	16.5	15.5	14.0	15.5	15.5	16.5
		最小	12.0	11.0	13.0	12.5	13.5	8.5	11.5	13.0	12.0	11.0	14.0	13.0	8.5
		平均	13.2	12.8	14.9	13.6	14.7	13.9	13.0	14.6	14.4	12.9	14.5	14.1	13.9

知多浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	24.0	27.0	29.0	33.0	34.0	32.0	27.0	23.0	14.0	13.0	15.0	15.0	34.0	
	最小	10.0	16.0	19.0	20.0	24.0	22.0	14.0	8.0	5.0	1.0	3.0	4.0	1.0	
	平均	17.4	22.2	23.3	28.5	31.0	27.0	21.5	14.1	9.6	5.7	6.5	9.4	18.0	
原水水温 (°C)	最大	16.5	21.5	24.0	26.0	29.0	28.0	24.0	18.0	13.0	9.5	8.0	11.0	29.0	
	最小	12.0	12.0	12.0	23.5	26.0	23.5	18.0	12.5	8.5	5.5	5.5	7.5	5.5	
	平均	14.2	18.7	21.3	24.7	27.1	25.8	21.4	15.3	10.6	7.0	6.5	9.0	16.8	
濁度 (度)	原水	最大	6.2	6.8	6.1	4.9	5.9	7.0	5.9	9.9	4.7	4.7	3.2	5.8	9.9
		最小	2.9	2.0	2.0	2.2	2.8	3.5	3.0	2.5	2.5	2.2	2.3	1.9	1.9
		平均	4.7	3.5	2.8	3.2	3.8	4.7	4.3	4.2	3.1	2.7	2.7	4.3	3.7
	配水	最大	6.8	5.9	5.0	3.6	5.1	5.6	5.3	3.5	3.0	1.8	1.9	4.0	6.8
		最小	1.9	2.2	1.5	2.0	2.0	2.4	2.1	0.9	0.8	0.8	1.2	1.3	0.8
		平均	3.1	3.8	3.0	3.0	3.4	4.5	3.8	2.2	1.7	1.3	1.5	2.8	2.8
pH値	原水	最大	7.5	7.3	7.2	7.1	7.3	7.3	7.5	8.0	8.1	7.7	7.6	7.7	8.1
		最小	7.2	7.1	7.0	6.9	6.9	7.1	7.2	7.5	7.6	7.5	7.5	7.5	6.9
		平均	7.4	7.2	7.1	7.0	7.1	7.2	7.3	7.7	7.8	7.6	7.5	7.6	7.4
	配水	最大	7.4	7.3	7.2	7.2	7.3	7.3	7.5	7.5	7.5	7.4	7.5	7.5	7.5
		最小	7.2	7.1	7.0	6.9	6.9	7.0	7.2	7.2	7.2	7.3	7.3	7.3	6.9
		平均	7.3	7.2	7.1	7.0	7.0	7.2	7.3	7.4	7.4	7.4	7.4	7.4	7.3
アルカ度 (mg/l)	原水	最大	16.0	16.5	17.0	17.0	17.5	18.0	15.5	17.5	18.0	16.0	18.0	18.5	18.5
		最小	14.0	14.0	14.5	15.0	15.5	14.5	14.0	14.5	15.5	14.5	15.5	15.5	14.0
		平均	14.8	15.1	15.8	15.8	16.4	16.7	14.6	16.2	16.9	15.2	16.7	16.7	15.9
	配水	最大	16.0	16.5	17.0	17.0	17.5	20.5	19.5	16.5	16.5	16.0	17.5	18.0	20.5
		最小	13.5	13.5	14.5	15.0	15.5	14.5	14.0	13.5	13.5	13.5	15.0	15.0	13.5
		平均	14.5	15.0	16.0	15.8	16.3	16.8	14.7	15.3	15.5	14.6	16.4	16.2	15.6

尾張西部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.4	28.2	28.9	32.0	33.7	30.0	25.2	20.0	14.1	11.8	9.5	13.7	33.7	
	最小	10.8	15.7	18.2	21.2	24.3	21.0	12.5	8.5	4.0	-0.1	1.3	4.8	-0.1	
	平均	17.0	21.5	23.7	27.2	29.6	26.2	20.7	14.2	9.0	5.3	5.5	9.5	17.5	
原水水温 (°C)	最大	15.5	20.0	24.5	25.5	28.4	26.8	20.3	15.0	11.0	8.1	7.3	11.4	28.4	
	最小	11.9	14.9	19.6	19.7	24.2	18.9	15.0	10.9	7.2	4.5	5.0	7.3	4.5	
	平均	13.5	17.3	21.7	23.3	26.4	23.0	18.2	13.1	8.9	6.0	6.0	8.9	15.5	
濁度 (度)	原水	最大	22.4	18.7	9.4	7.1	16.0	78.0	11.0	4.1	16.8	4.8	5.7	2.8	78.0
		最小	1.2	1.1	1.6	2.0	2.0	1.8	1.4	1.0	1.4	1.3	1.1	1.2	1.0
		平均	4.7	4.4	3.8	3.8	5.2	12.0	3.6	2.1	4.4	2.0	2.0	1.9	4.2
	配水	最大	0.6	0.4	0.5	0.5	0.4	0.4	0.4	0.4	0.5	0.5	0.6	0.8	0.8
		最小	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.2	0.2	0.2	0.3	0.3	0.1
		平均	0.4	0.3	0.3	0.2	0.2	0.2	0.3	0.3	0.4	0.4	0.4	0.5	0.3
pH値	原水	最大	7.5	7.4	7.4	7.3	7.4	7.4	7.4	7.5	7.4	7.7	7.7	7.6	7.7
		最小	7.0	6.9	7.0	7.0	7.0	6.8	7.0	7.2	7.1	7.2	7.2	7.2	6.8
		平均	7.2	7.2	7.2	7.1	7.2	7.1	7.2	7.3	7.2	7.4	7.5	7.4	7.3
	配水	最大	7.3	7.3	7.3	7.2	7.3	7.2	7.2	7.2	7.2	7.4	7.3	7.4	7.4
		最小	7.1	7.0	7.0	6.9	7.0	7.0	7.0	7.1	7.0	7.2	7.2	7.1	6.9
		平均	7.2	7.1	7.2	7.1	7.2	7.1	7.1	7.2	7.1	7.3	7.3	7.2	7.2
アルカ度 (mg/l)	原水	最大	20.5	20.0	22.0	19.0	22.0	21.5	20.0	22.5	20.0	20.5	21.0	23.0	23.0
		最小	12.5	11.0	14.0	15.0	13.5	10.0	14.0	16.0	11.0	12.0	14.0	15.0	10.0
		平均	17.2	16.1	19.8	17.1	18.3	17.1	17.1	19.3	16.8	17.6	18.9	19.6	17.9
	配水	最大	19.0	19.0	20.5	17.5	19.0	20.0	17.5	20.0	19.0	18.5	19.0	20.5	20.5
		最小	12.0	10.0	13.5	11.0	13.0	10.0	13.5	15.0	12.0	11.0	13.0	13.0	10.0
		平均	15.3	14.7	18.3	15.2	16.6	16.0	15.6	17.1	15.7	15.5	17.1	17.7	16.2

安城浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	23.0	28.6	29.5	34.0	34.5	31.9	27.5	20.2	16.5	12.1	10.9	15.2	34.5	
	最小	11.6	17.2	18.9	20.9	26.2	21.6	16.1	9.1	6.7	1.7	4.6	6.8	1.7	
	平均	18.3	23.1	25.1	29.4	31.7	27.4	22.3	15.1	10.3	6.6	7.4	10.7	19.0	
原水水温 (°C)	最大	17.2	20.9	22.8	26.3	27.0	26.1	21.1	18.0	11.0	7.1	7.1	11.7	27.0	
	最小	11.6	15.3	19.9	21.6	24.1	20.0	16.6	11.4	7.0	4.4	5.0	6.5	4.4	
	平均	13.9	17.8	21.5	24.6	25.9	23.3	19.0	13.6	8.8	5.7	5.7	8.6	15.7	
濁度 (度)	原水	最大	9.0	28.0	18.0	14.0	16.0	83.0	18.0	4.0	31.0	7.0	15.0	9.0	83.0
		最小	2.0	4.0	2.0	2.0	2.0	1.0	2.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	6.0	8.0	5.0	4.0	5.0	12.0	6.0	2.0	4.0	3.0	3.0	3.0	5.1
	配水	最大	1.0	1.0	1.0	1.0	1.0	1.0	1.0	2.0	1.0	1.0	2.0	1.0	2.0
		最小	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
		平均	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
pH値	原水	最大	7.9	7.3	7.3	7.4	7.4	7.4	7.5	7.6	7.5	7.7	7.7	7.7	7.9
		最小	7.1	7.1	7.0	7.1	7.0	6.9	7.2	7.2	7.2	7.2	7.4	7.3	6.9
		平均	7.3	7.3	7.2	7.2	7.3	7.2	7.4	7.4	7.4	7.4	7.5	7.4	7.3
	配水	最大	7.1	7.1	7.0	7.0	7.0	7.0	7.0	7.1	7.2	7.2	7.2	7.2	7.2
		最小	6.9	6.8	6.7	6.7	6.7	6.6	6.7	6.9	6.9	7.0	7.1	7.0	6.6
		平均	7.0	6.9	6.9	6.9	6.8	6.8	6.9	7.0	7.1	7.1	7.2	7.1	7.0
アルカ度 (mg/l)	原水	最大	24.0	21.5	24.0	23.5	22.5	22.5	22.0	24.5	26.5	25.0	25.0	25.5	26.5
		最小	19.0	16.5	20.0	20.0	17.5	16.5	19.0	22.0	17.0	19.0	20.0	21.0	16.5
		平均	21.7	19.1	21.4	21.9	20.6	20.0	20.8	23.6	22.8	21.2	22.6	22.9	21.6
	配水	最大	19.0	17.0	19.0	19.0	18.0	18.0	18.0	20.0	21.0	21.0	21.0	20.5	21.0
		最小	15.0	12.0	15.5	15.0	12.0	11.0	13.0	17.0	15.5	17.0	17.0	17.0	11.0
		平均	17.4	14.9	16.9	17.1	15.5	15.2	15.8	18.9	18.9	18.3	18.7	18.7	17.2

豊橋南部浄水場

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.2	26.3	27.3	31.0	32.6	31.2	26.4	19.7	16.4	11.4	12.5	14.8	32.6	
	最小	11.7	15.4	19.3	19.9	25.4	22.7	15.1	8.7	6.1	0.6	3.8	5.7	0.6	
	平均	17.4	21.7	24.0	27.7	30.0	26.5	21.4	14.4	10.1	6.3	6.8	9.7	18.0	
原水水温 (°C)	最大	15.1	18.2	21.3	23.7	27.0	25.5	23.5	18.5	13.8	10.1	7.5	10.0	27.0	
	最小	10.8	15.2	17.5	21.3	23.7	22.6	18.6	13.5	10.3	6.6	6.3	7.5	6.3	
	平均	12.8	16.8	19.2	22.6	24.4	24.0	21.3	16.0	11.7	8.0	6.9	8.6	16.0	
濁度 (度)	原水	最大	5.2	6.0	5.3	4.0	5.3	28.4	2.0	2.0	2.3	2.1	3.3	2.5	28.4
		最小	1.9	2.2	1.0	1.3	1.5	1.1	0.8	1.1	1.2	1.2	1.6	1.3	0.8
		平均	2.7	3.0	2.0	2.1	2.3	3.8	1.2	1.6	1.8	1.6	2.1	1.7	2.2
	配水	最大	0.2	0.1	0.5	0.5	0.3	0.4	0.3	0.3	0.2	0.1	0.1	0.1	0.5
		最小	0.0	0.0	0.0	0.1	0.0	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0
		平均	0.0	0.1	0.1	0.2	0.1	0.2	0.2	0.2	0.1	0.0	0.0	0.0	0.1
pH値	原水	最大	7.5	7.6	7.4	7.5	8.1	8.8	7.6	7.8	7.8	7.7	7.6	7.7	8.8
		最小	7.1	7.2	7.2	7.0	7.1	7.1	7.1	7.4	7.5	7.4	7.5	7.5	7.0
		平均	7.3	7.4	7.2	7.3	7.5	7.5	7.3	7.6	7.6	7.5	7.5	7.6	7.4
	配水	最大	7.2	7.2	7.1	7.2	7.2	7.5	7.2	7.2	7.2	7.1	7.2	7.2	7.5
		最小	7.0	6.9	6.8	6.9	7.0	6.9	7.0	7.1	7.0	7.0	6.9	7.0	6.8
		平均	7.0	7.0	7.0	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1	7.1
アルカ度 (mg/l)	原水	最大	19.0	19.0	19.0	27.0	28.5	27.0	21.0	22.5	22.5	22.0	21.5	24.5	28.5
		最小	14.5	13.5	14.5	16.0	17.5	15.0	17.5	17.0	17.5	17.0	16.0	17.5	13.5
		平均	16.9	16.4	16.4	22.1	19.7	19.3	19.6	20.4	19.7	19.8	19.4	20.3	19.2
	配水	最大	14.0	14.5	15.5	21.0	22.0	21.0	16.5	17.0	17.0	17.0	16.5	19.0	22.0
		最小	11.5	10.5	10.5	13.5	13.0	12.0	14.0	13.0	13.0	13.0	12.0	12.5	10.5
		平均	13.0	12.5	12.6	17.6	14.0	14.7	15.4	15.1	14.8	15.2	15.0	15.6	14.6

蒲郡浄水場(工水)

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月	年度集計	
気温 (°C)	最大	22.0	25.5	27.0	31.0	32.0	30.0	26.0	20.0	15.5	12.0	13.0	14.0	32.0	
	最小	13.5	18.0	20.0	22.0	26.0	23.0	16.0	10.0	8.5	2.5	6.0	8.0	2.5	
	平均	17.7	21.7	23.7	28.0	29.8	26.1	21.8	15.5	11.7	8.1	8.5	10.9	18.6	
原水水温 (°C)	最大	15.5	19.5	20.0	23.5	25.0	22.8	21.7	18.2	14.0	11.5	9.2	11.5	25.0	
	最小	12.4	14.4	16.0	20.1	22.1	21.5	18.5	13.4	10.6	7.3	7.4	8.8	7.3	
	平均	14.1	16.7	18.3	22.0	23.8	22.2	20.2	15.7	11.9	9.1	8.1	10.1	16.0	
濁度 (度)	原水	最大	2.0	3.3	5.6	2.4	3.6	4.1	1.6	1.1	0.7	1.1	1.1	4.0	5.6
		最小	0.4	0.3	0.6	0.6	1.0	0.5	0.3	0.1	0.3	0.2	0.3	0.3	0.1
		平均	0.9	1.0	1.6	1.3	1.6	1.3	0.8	0.6	0.5	0.5	0.6	0.9	1.0
	配水	最大	0.4	0.9	0.6	0.4	0.8	0.6	0.4	0.2	0.3	0.2	0.2	0.4	0.9
		最小	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
		平均	0.2	0.2	0.4	0.2	0.2	0.2	0.2	0.1	0.1	0.1	0.1	0.1	0.2
pH値	原水	最大	7.3	7.3	7.3	7.6	7.5	7.5	7.4	7.5	7.5	7.4	7.5	7.6	
		最小	7.2	7.2	7.1	7.2	7.2	7.2	7.2	7.4	7.4	7.4	7.3	7.3	
		平均	7.3	7.2	7.2	7.4	7.3	7.3	7.3	7.4	7.4	7.4	7.3	7.4	
	配水	最大	7.3	7.4	7.3	7.4	7.3	7.3	7.4	7.4	7.4	7.4	7.3	7.4	
		最小	7.2	7.1	7.1	7.2	7.1	7.1	7.1	7.1	7.2	7.1	7.1	7.2	
		平均	7.3	7.2	7.2	7.3	7.2	7.2	7.2	7.3	7.3	7.3	7.2	7.3	
アルカリ度 (mg/l)	原水	最大	22.0	25.0	24.0	35.0	34.0	27.0	25.0	26.0	26.0	24.0	25.0	35.0	
		最小	18.0	18.0	17.0	18.0	18.0	18.0	20.0	21.0	21.0	19.0	20.0	17.0	
		平均	19.8	20.8	19.6	27.4	22.2	21.5	22.3	23.5	23.6	22.5	22.3	22.1	
	配水	最大	22.0	22.0	22.0	33.0	30.0	22.0	23.0	23.0	23.0	22.0	22.0	22.0	
		最小	17.0	17.0	16.0	17.0	16.0	17.0	18.0	20.0	20.0	17.0	19.0	18.0	
		平均	18.6	19.5	18.6	25.0	20.3	19.6	20.4	21.4	21.2	20.0	20.1	19.6	