

平成12年度 水量管理表

H12_犬山.xlsx

| | | 4月 | 5月 | 6月 | 7月 | 8月 | 9月 | 10月 | 11月 | 12月 | 1月 | 2月 | 3月 | 計 |
|-------|-------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|-----------|------------|
| A 取水量 | 月間水量 | 5,878,800 | 6,290,300 | 6,355,700 | 7,425,700 | 7,429,100 | 6,452,800 | 6,347,700 | 5,960,400 | 6,201,900 | 5,884,700 | 5,546,300 | 6,021,800 | 75,795,200 |
| | 日最大水量 | 206,900 | 224,300 | 237,500 | 259,400 | 259,400 | 234,000 | 220,200 | 208,700 | 224,400 | 207,700 | 211,900 | 205,700 | 259,400 |
| | 日最小水量 | 175,100 | 180,300 | 177,700 | 212,000 | 219,500 | 178,100 | 174,300 | 180,600 | 177,500 | 155,900 | 182,100 | 177,800 | 155,900 |
| | 日平均水量 | 195,960 | 202,913 | 211,857 | 239,539 | 239,648 | 215,093 | 204,765 | 198,680 | 200,061 | 189,829 | 198,082 | 194,252 | 207,557 |
| 還元水量 | 月間水量 | 197,900 | 226,900 | 200,400 | 211,600 | 213,600 | 207,300 | 197,400 | 196,500 | 185,300 | 171,100 | 185,000 | 207,600 | 2,400,600 |
| | 日最大水量 | 10,400 | 12,200 | 13,000 | 10,800 | 9,700 | 10,200 | 9,400 | 9,900 | 8,900 | 5,519 | 13,800 | 10,700 | 13,800 |
| | 日最小水量 | 3,600 | 3,800 | 1,500 | 2,300 | 3,200 | 1,700 | 2,900 | 3,400 | 2,700 | 1,700 | 1,700 | 2,800 | 1,500 |
| | 日平均水量 | 6,597 | 7,319 | 6,680 | 6,826 | 6,890 | 6,910 | 6,368 | 6,550 | 5,977 | 5,519 | 6,607 | 6,697 | 6,578 |
| B 送水量 | 月間水量 | 5,872,850 | 6,284,010 | 6,349,400 | 7,418,130 | 7,421,500 | 6,446,190 | 6,341,340 | 5,954,260 | 6,195,560 | 5,878,450 | 5,540,670 | 6,015,900 | 75,718,260 |
| | 日最大水量 | 206,720 | 224,110 | 237,310 | 259,100 | 259,150 | 233,730 | 219,940 | 208,490 | 224,160 | 207,480 | 211,700 | 205,470 | 259,150 |
| | 日最小水量 | 174,890 | 180,110 | 177,550 | 211,760 | 219,330 | 177,930 | 174,120 | 180,390 | 177,350 | 155,750 | 181,900 | 177,580 | 155,750 |
| | 日平均水量 | 195,762 | 202,710 | 211,647 | 239,295 | 239,403 | 214,873 | 204,559 | 198,475 | 199,857 | 189,627 | 197,881 | 194,061 | 207,346 |
| C 給水量 | 月間水量 | 5,831,729 | 6,240,031 | 6,304,970 | 7,366,225 | 7,369,537 | 6,401,070 | 6,296,960 | 5,912,571 | 6,152,216 | 5,837,284 | 5,501,602 | 5,973,194 | 75,187,389 |
| | 日最大水量 | 205,273 | 222,543 | 235,647 | 257,289 | 257,334 | 232,096 | 218,398 | 207,035 | 222,591 | 206,027 | 210,221 | 204,030 | 257,334 |
| | 日最小水量 | 173,666 | 178,849 | 176,306 | 210,276 | 217,796 | 176,680 | 172,901 | 179,123 | 176,106 | 154,657 | 180,325 | 176,334 | 154,657 |
| | 日平均水量 | 194,391 | 201,291 | 210,166 | 237,620 | 237,727 | 213,369 | 203,128 | 197,086 | 198,459 | 188,299 | 196,486 | 192,684 | 205,892 |

平成12年度 水質管理表

H12_犬山.xlsx

| | | 4月 | 5月 | 6月 | 7月 | 8月 | 9月 | 10月 | 11月 | 12月 | 1月 | 2月 | 3月 | 計 | |
|------------------------------------|----|------|------|------|------|------|------|-------|------|------|------|------|------|------|-------|
| 気温 (°C) | 最大 | 18.0 | 25.3 | 27.0 | 33.0 | 31.5 | 30.5 | 25.9 | 21.3 | 13.1 | 9.5 | 11.7 | 16.0 | 33.0 | |
| | 最小 | 9.0 | 15.0 | 18.0 | 23.3 | 26.5 | 19.3 | 14.3 | 8.5 | 0.6 | -0.4 | 1.0 | 0.0 | -0.4 | |
| | 平均 | 15.0 | 20.8 | 23.3 | 28.9 | 29.6 | 25.3 | 19.8 | 14.4 | 7.4 | 3.6 | 5.9 | 8.9 | 16.9 | |
| 原水水温 (°C) | 最大 | 11.0 | 16.4 | 20.0 | 23.2 | 24.1 | 24.0 | 17.4 | 15.8 | 9.2 | 5.6 | 6.0 | 8.7 | 24.1 | |
| | 最小 | 7.0 | 11.5 | 16.0 | 16.5 | 22.0 | 17.7 | 14.2 | 9.1 | 5.7 | 2.7 | 4.0 | 4.7 | 2.7 | |
| | 平均 | 9.3 | 14.1 | 17.3 | 20.7 | 23.3 | 20.3 | 16.6 | 12.1 | 6.9 | 4.1 | 4.5 | 6.3 | 13.0 | |
| 濁度 (度) | 原水 | 最大 | 11.3 | 20.0 | 80.0 | 7.6 | 11.6 | 324.0 | 12.2 | 32.0 | 3.9 | 15.0 | 12.6 | 18.0 | 324.0 |
| | | 最小 | 3.0 | 3.0 | 2.0 | 1.0 | 2.1 | 2.1 | 1.3 | 1.0 | 1.7 | 1.9 | 2.2 | 2.6 | 1.0 |
| | | 平均 | 6.4 | 5.3 | 13.3 | 3.5 | 4.4 | 26.1 | 3.7 | 7.4 | 2.7 | 4.2 | 5.4 | 4.3 | 7.2 |
| | 浄水 | 最大 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| | | 最小 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| | | 平均 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| 色度 (度) | 原水 | 最大 | 12.0 | 10.0 | 90.0 | 8.0 | 12.0 | 445.0 | 11.0 | 33.0 | 3.0 | 13.0 | 12.0 | 16.0 | 445.0 |
| | | 最小 | 1.0 | 2.0 | 3.0 | 1.0 | 1.0 | 1.0 | 0.0 | 0.0 | 1.0 | 1.0 | 1.0 | 1.0 | 0.0 |
| | | 平均 | 4.8 | 5.2 | 14.6 | 3.9 | 5.0 | 28.5 | 3.1 | 6.2 | 1.6 | 3.0 | 4.1 | 3.0 | 6.9 |
| | 浄水 | 最大 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| | | 最小 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| | | 平均 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| pH | 原水 | 最大 | 7.0 | 7.0 | 6.9 | 6.9 | 6.9 | 7.0 | 7.1 | 7.0 | 7.0 | 7.1 | 7.0 | 7.0 | 7.1 |
| | | 最小 | 6.8 | 6.9 | 6.7 | 6.8 | 6.8 | 6.5 | 6.8 | 6.8 | 6.9 | 6.9 | 6.8 | 6.8 | 6.5 |
| | | 平均 | 6.9 | 6.9 | 6.9 | 6.9 | 6.9 | 6.9 | 7.0 | 6.9 | 6.9 | 6.9 | 6.9 | 6.9 | 6.9 |
| | 浄水 | 最大 | 7.1 | 7.1 | 7.0 | 7.1 | 7.1 | 7.1 | 7.1 | 7.1 | 7.1 | 7.1 | 7.0 | 7.1 | 7.1 |
| | | 最小 | 6.9 | 6.9 | 7.0 | 7.0 | 6.9 | 6.9 | 7.0 | 7.0 | 7.0 | 7.0 | 6.9 | 7.0 | 6.9 |
| | | 平均 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 | 7.0 |
| アルカリ度 (mg/l) | 原水 | 最大 | 18.0 | 18.0 | 18.0 | 19.0 | 20.0 | 21.0 | 21.0 | 19.0 | 22.0 | 20.5 | 20.0 | 19.0 | 22.0 |
| | | 最小 | 11.0 | 15.0 | 9.0 | 12.0 | 15.0 | 7.5 | 15.0 | 8.5 | 15.5 | 14.0 | 15.0 | 13.0 | 7.5 |
| | | 平均 | 14.8 | 16.5 | 15.4 | 16.6 | 17.6 | 15.9 | 18.0 | 15.0 | 19.0 | 17.8 | 18.2 | 16.2 | 16.7 |
| | 浄水 | 最大 | 18.0 | 19.0 | 19.0 | 20.0 | 20.5 | 21.0 | 22.0 | 19.0 | 22.0 | 21.0 | 21.0 | 19.0 | 22.0 |
| | | 最小 | 13.0 | 15.5 | 12.0 | 13.5 | 15.5 | 10.5 | 15.0 | 11.0 | 16.0 | 15.0 | 15.0 | 14.0 | 10.5 |
| | | 平均 | 16.0 | 17.4 | 16.7 | 17.4 | 18.5 | 17.0 | 18.5 | 15.5 | 19.3 | 18.2 | 18.6 | 16.6 | 17.5 |
| KMnO ₄ 消費量 (mg/l) | 原水 | 最大 | 5.6 | 5.3 | 10.9 | 7.8 | 6.6 | 28.3 | 4.8 | 9.4 | 6.1 | 10.3 | 6.3 | 6.6 | 28.3 |
| | | 最小 | 1.8 | 3.1 | 3.1 | 2.6 | 2.8 | 3.4 | 2.7 | 2.4 | 3.0 | 3.1 | 2.8 | 2.5 | 1.8 |
| | | 平均 | 3.6 | 3.9 | 5.1 | 4.2 | 4.4 | 6.2 | 3.6 | 4.0 | 3.7 | 4.5 | 4.1 | 3.4 | 4.2 |
| | 浄水 | 最大 | 2.2 | 1.6 | 1.9 | 2.6 | 2.5 | 2.5 | 1.8 | 1.2 | 2.4 | 2.4 | 2.2 | 2.5 | 2.6 |
| | | 最小 | 0.2 | 0.9 | 0.6 | 0.6 | 0.6 | 0.6 | 0.8 | 0.6 | 0.6 | 1.2 | 1.0 | 0.3 | 0.2 |
| | | 平均 | 0.9 | 1.2 | 1.3 | 1.5 | 1.5 | 1.5 | 1.2 | 1.0 | 1.4 | 1.8 | 1.6 | 1.4 | 1.4 |
| 残留塩素 (mg/l) | 浄水 | 最大 | 0.7 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.7 |
| | | 最小 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.6 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| | | 平均 | 0.6 | 0.6 | 0.5 | 0.5 | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 | 0.5 | 0.6 | 0.6 | 0.6 |

平成12年度 排水処理管理表

| | | 4月 | 5月 | 6月 | 7月 | 8月 | 9月 | 10月 | 11月 | 12月 | 1月 | 2月 | 3月 | 計 | |
|----------|---------------------|----------------|---------|---------|---------|---------|---------|---------|--------|---------|---------|---------|---------|----------|----------|
| 泥掻寄機稼働日数 | 日 | 30 | 31 | 30 | 31 | 31 | 30 | 31 | 30 | 31 | 31 | 28 | 31 | 365 | |
| 汚泥処理量 | 機械 | m ³ | 2,962.2 | 2,868.6 | 3,246.6 | 2,824.3 | 3,442.0 | 2,903.8 | 951.6 | 1,762.3 | 2,621.9 | 2,572.0 | 3,698.7 | 3,548.1 | 33,402.1 |
| | 天日 | m ³ | | | | | | | | | | | | | 0.0 |
| 汚泥平均濃度 | % | 1.7 | 2.3 | 2.2 | 3.0 | 2.1 | 6.7 | 14.9 | 9.5 | 5.6 | 4.5 | 2.3 | 2.2 | 4.8 | |
| ケーキ重量 | t | 193.49 | 198.26 | 213.71 | 191.17 | 196.17 | 255.33 | 240.20 | 260.25 | 298.33 | 275.44 | 258.26 | 230.49 | 2,811.10 | |
| ケーキ平均含水率 | % | 70.1 | 67.2 | 67.8 | 59.3 | 65.7 | 51.8 | 41.2 | 49.2 | 54.1 | 58.5 | 69.1 | 69.6 | 60.3 | |
| 乾燥発生土量 | t | 51.28 | 64.95 | 70.31 | 80.18 | 70.92 | 150.12 | 148.51 | 147.34 | 155.07 | 130.00 | 92.59 | 76.42 | 1,237.69 | |
| 発生土量 | m ³ | 262.9 | 256.1 | 278.3 | 240.8 | 251.2 | 295.5 | 251.8 | 299.1 | 340.2 | 333.5 | 330.7 | 257.2 | 3,397.3 | |
| 発生土場外搬出量 | m ³ | 0.0 | 680.0 | 300.0 | 0.0 | 338.0 | 262.0 | 0.0 | 0.0 | 10.0 | 30.0 | 300.0 | 710.0 | 2,630.0 | |
| 有効利用土量 | m ³ | 0.0 | 680.0 | 300.0 | 0.0 | 338.0 | 262.0 | 0.0 | 0.0 | 10.0 | 30.0 | 300.0 | 710.0 | 2,630.0 | |
| 産廃土量 | m ³ | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| 泥水搬出量 | m ³ | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | |
| ケーキヤード残量 | m ³ | 583.8 | 159.9 | 138.2 | 379.0 | 292.2 | 325.7 | 577.5 | 876.6 | 1,206.8 | 1,510.2 | 1,540.9 | 1,088.2 | | |
| 脱水機稼働日数 | 日 | 4 | 3 | 4 | 2 | 4 | 3 | 2 | 2 | 3 | 2 | 3 | 2 | 34 | |
| 運転回数 | 回 | 8 | 6 | 8 | 4 | 8 | 6 | 4 | 4 | 6 | 4 | 6 | 4 | 68 | |
| 平均運転時間 | 分 | 130.0 | 130.0 | 130.0 | 120.0 | 130.0 | 104.0 | 58.5 | 66.0 | 100.0 | 100.0 | 121.7 | 127.5 | 109.8 | |
| 平均ろ速 | kg/m ² h | 0.2 | 0.3 | 0.3 | 0.4 | 0.2 | 0.7 | 3.8 | 2.2 | 0.9 | 0.7 | 0.3 | 0.3 | 0.9 | |
| 脱水機稼働日数 | 日 | 24 | 21 | 24 | 19 | 25 | 22 | 10 | 17 | 17 | 19 | 22 | 24 | 244 | |
| 運転回数 | 回 | 12 | 12 | 13 | 12 | 12 | 16 | 10 | 16 | 17 | 17 | 17 | 16 | 170 | |
| 平均運転時間 | 分 | 1,602.0 | 1,332.0 | 1,320.0 | 1,240.8 | 1,512.0 | 840.0 | 312.0 | 594.0 | 828.0 | 936.0 | 1,482.0 | 1,578.0 | 1,131.4 | |
| 平均ろ速 | kg/m ² h | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.5 | 1.6 | 0.7 | 0.5 | 0.4 | 0.2 | 0.1 | 0.4 | |
| 脱水機稼働日数 | 日 | 24 | 22 | 26 | 21 | 21 | 19 | 16 | 16 | 19 | 20 | 23 | 23 | 250 | |
| 運転回数 | 回 | 14 | 14 | 15 | 12 | 13 | 14 | 1 | 15 | 19 | 18 | 18 | 16 | 169 | |
| 平均運転時間 | 分 | 1,638.0 | 1,338.0 | 1,362.0 | 1,236.0 | 1,506.0 | 816.0 | 288.0 | 570.0 | 774.0 | 876.0 | 1,422.0 | 1,488.0 | 1,109.5 | |
| 平均ろ速 | kg/m ² h | 0.1 | 0.2 | 0.2 | 0.2 | 0.2 | 0.5 | 1.7 | 0.7 | 0.5 | 0.4 | 0.2 | 0.1 | 0.4 | |