

浄水場原水 試験結果書

単位：ng/L

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
高蔵寺浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
尾張東部浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
上野浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
知多浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
犬山浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
尾張西部浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊田浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
幸田浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊橋浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊橋南部浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊川浄水場原水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								

定量下限値：2ng/L

浄水場浄水 試験結果書

単位：ng/L

		4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
高蔵寺浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
尾張東部浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
上野浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
知多浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
犬山浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
尾張西部浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊田浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
幸田浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊橋浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊橋南部浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								
豊川浄水場浄水	PFOS	ng/L	< 2	< 2	< 2								
	PFOA	ng/L	< 2	< 2	< 2								
	PFHxS	ng/L	< 2	< 2	< 2								

定量下限値：2ng/L

主要河川（監視地点）試験結果書

			4月	5月	6月	7月	8月	9月	10月	11月	12月	1月	2月	3月
兼山取水口	PFOS	ng/L		< 2										
	PFOA	ng/L		< 2										
	PFHxS	ng/L		< 2										
長良川取水口	PFOS	ng/L		< 2										
	PFOA	ng/L		2										
	PFHxS	ng/L		< 2										
岩倉取水口	PFOS	ng/L		< 2										
	PFOA	ng/L		< 2										
	PFHxS	ng/L		< 2										
細川頭首工	PFOS	ng/L		< 2										
	PFOA	ng/L		< 2										
	PFHxS	ng/L		< 2										
大野頭首工	PFOS	ng/L		< 2										
	PFOA	ng/L		< 2										
	PFHxS	ng/L		< 2										
森岡取水場	PFOS	ng/L		< 2										
	PFOA	ng/L		< 2										
	PFHxS	ng/L		< 2										

定量下限値：2ng/L